

7 DIRECT TESTIMONY
8 OF ARNE OLSON
9 ON BEHALF OF NORTHWESTERN ENERGY
10

11 TABLE OF CONTENTS

12	<u>Description</u>	<u>Starting Page No.</u>
13	Witness Information	2
14	Purpose of Testimony	6
15	Capacity Contribution of Intermittent Renewables and Energy Storage	7
16	E3’s Incremental Effective Load Carrying Capability Study	15
17	ELCC Calculation Results	24
18	Observations from ELCC Calculation Results	27
19		
20	<u>Exhibits</u>	
21	Arne Olson Resume	Exhibit AO-1
22	ELCC Study Results (July 2020)	Exhibit AO-2
23	ELCC Study Results (November 2020)	Exhibit AO-3
24	Proposal-specific Incremental ELCC Calculations (Jan. 2021)	Exhibit AO-4
25		

1 **Witness Information**

2 **Q. Please provide your name, employer, and title.**

3 **A.** My name is Arne Olson. My business address is 44 Montgomery Street,
4 Suite 1500, San Francisco, CA 94104. I am employed by Energy +
5 Environmental Economics Inc. ("E3"), where I am a Senior Partner.

6
7 **Q. Please describe your relevant experience and education.**

8 **A.** I have over 30 years of experience in the electric utility business in
9 consulting and state government. Since joining E3 in 2002, I have worked
10 extensively in the areas of resource planning, asset valuation,
11 transmission, market design, and energy policy. I currently lead E3's
12 Integrated System Planning practice and contribute frequently to projects
13 across many practice areas. Prior to joining E3 in 2002, I served for six
14 years as an energy policy specialist at the Washington Department of
15 Commerce.

16 I received a Master of Science degree in International Energy
17 Management & Policy from the University of Pennsylvania and Bachelor of
18 Science degrees in Mathematical Sciences and Statistics from the
19 University of Washington. The attached résumé (Exhibit AO-1) further
20 describes my qualifications, experience, and publications.

21 I have served as the lead investigator in developing integrated resource
22 plans ("IRP") for utilities and state agencies across North America. Much
23 of my resource planning work has focused on helping utilities analyze the

1 impacts of higher penetrations of variable renewable resources on their
2 operations and investment decisions. Some examples of current and past
3 projects include:

- 4 • I am a co-author of the 2016 Report Number 6 of the Lawrence
5 Berkeley National Laboratory's "Future Electric Utility Regulation
6 Series," entitled "The Future of Integrated Resource Planning."
- 7 • I led a team that supported Nova Scotia Power's IRP focusing on the
8 recently established provincial goal of achieving net zero carbon
9 emissions by 2050.
- 10 • For the Sacramento Municipal Utilities District ("SMUD"), I led the
11 development of their 2018 IRP which considered scenarios and
12 resource portfolios for meeting California's and SMUD's own
13 renewables goals including 100% renewables by 2040, as well as a
14 2020 study of resource portfolios for achieving the utility's net zero
15 carbon emissions goal by 2030.
- 16 • For Xcel Energy, I led an effort to support development of Northern
17 States Power's 2018-2019 IRP examining high renewable scenarios
18 within the context of the company's stated goal of completely
19 decarbonizing its electric resource portfolio by 2050.
- 20 • For a group of utilities in the Pacific Northwest, I led studies in 2017
21 and 2018 that examined scenarios achieving 50% renewables and up
22 to 100% carbon reductions across the region, focusing on policy
23 mechanisms to achieve the goals at least cost and on the nature and

1 quantity of complementary resources that are needed to maintain
2 reliable electric service.

- 3 • I have led several studies examining the means to ensure resource
4 adequacy under high renewable power systems, including: a 2020
5 study of the New England system, undertaken in partnership with
6 former U.S. Energy Secretary Dr. Ernest Moniz, entitled “Net Zero New
7 England: Ensuring Electric Reliability in a Low-Carbon Future”; a 2019
8 study of the California system entitled “Long-Run Resource Adequacy
9 under Deep Decarbonization Pathways Scenarios for California”,
10 funded by the Calpine Corporation; and a 2018 study entitled
11 “Resource Adequacy in the Pacific Northwest” funded by a coalition of
12 13 publicly-owned and investor-owned utilities including NorthWestern
13 Energy. In 2019, I also supported the Northwest Power Pool’s effort to
14 develop a regional resource adequacy program in the Pacific
15 Northwest, which later became the Western Resource Adequacy
16 Program (WRAP).
- 17 • In 2018, I led a study of the value of partially- and fully-dispatchable
18 solar and solar + storage power plants on the Tampa Electric
19 Company (“TECO”) system. The study was funded by First Solar, but it
20 involved extensive participation by a wide range of TECO staff and
21 included detailed TECO power system data. First Solar and TECO
22 jointly received a “2018 Top Innovators” award from Public Utilities
23 Fortnightly in conjunction with the study, and TECO was selected as a

1 finalist for a 2019 Platts Global Energy Award in the “Grid Edge”
2 category.

- 3 • For a group comprising the five largest utilities in California (Los
4 Angeles Department of Water and Power, Pacific Gas and Electric
5 Company, Sacramento Municipal Utilities District, San Diego Gas &
6 Electric Company, and Southern California Edison), I led a landmark
7 2014 study of the feasibility, cost implications, and complementary
8 measures for achieving 50% renewables by 2030.
- 9 • I have participated in several other E3 resource planning studies of
10 achieving very high renewable penetrations for the Hawaiian Electric
11 Company, the New York State Energy Research and Development
12 Authority, and Arizona Public Service Company.
- 13 • Since 2017, I have led a team at E3 that supports the California Public
14 Utilities Commission staff in developing a Reference System Plan for
15 California and designing and implementing IRP standards for California
16 load-serving entities.

17
18 **Q. Have you previously testified in front of the Montana Public Service**
19 **Commission (“Commission”)?**

20 **A.** No, I have not. However, I was invited by Commission staff to present to
21 the Commission in June 2017 regarding “Resource Adequacy and
22 Planning Reserve Margins.” I also presented results of our study
23 “Resource Adequacy in the Pacific Northwest” to the Commission in April

1 2019. I have provided expert witness testimony to the California Public
2 Utilities Commission, the California Energy Commission, the Oregon
3 Public Utility Commission, the Colorado Public Utilities Commission, the
4 New Mexico Public Regulation Commission, the Georgia Public Service
5 Commission, the South Carolina Public Service Commission, the Alberta
6 Energy and Utilities Board, the Nova Scotia Utility and Review Board,
7 Colorado Superior Court, and the Ontario Superior Court of Justice.

8 **Purpose of Testimony**

9 **Q. What is the purpose of your testimony in this docket?**

10 **A.** The purpose of my testimony is to describe the methods and results of
11 E3's incremental Effective Load Carrying Capability ("ELCC") studies
12 conducted for NorthWestern and used by NorthWestern in its
13 2020 Supplement to its 2019 Electricity Supply Resource Procurement
14 Plan ("2020 Supplement") and January 2020 Request for Proposals for
15 long-term capacity resources ("RFP"). NorthWestern evaluated the
16 resources proposed in response to the RFP based in part on the amount
17 of effective capacity each resource could be expected to contribute toward
18 meeting the utility's resource adequacy needs, which is often referred to
19 as the resource's "capacity contribution."

20
21 NorthWestern used E3's ELCC studies to assess the capacity contribution
22 from stand-alone wind, solar, energy storage, and hybrid resources of
23 various configurations. In NorthWestern's 2020 Supplement, ELCC values

1 were used for hydro, wind, solar and storage; forced outage de-rates were
2 used for the capacity contributions of coal, natural gas, and thermal QFs.

3

4 **Q. What was the scope of E3's ELCC study for NorthWestern?**

5 **A.** NorthWestern retained E3 to calculate ELCC values for dispatch-limited
6 resources for the purpose of evaluating those resources in its 2020
7 Supplement and RFP, as described in the Direct Testimony of Michael S.
8 Babineaux. The resources considered in E3's analysis included stand-
9 alone storage (ranging from 3 hours to 10 hours in duration), solar
10 photovoltaic (PV), wind, and solar plus storage and wind plus storage
11 hybrid resources of various configurations, including specific offers
12 received by NorthWestern. E3 tested a range of penetration levels across
13 those resources to determine incremental ELCCs for various levels of
14 potential resource additions.

15

16 **Capacity Contribution of Intermittent Renewables and Energy Storage**

17 **Q. How do dispatch-limited resources differ from firm resources in their**
18 **ability to contribute to resource adequacy?**

19 **A.** Unlike conventional firm resources, dispatch-limited resources have
20 physical limitations that prevent them from being operated continuously at
21 full capacity to meet demand. These constraints may take multiple forms:
22 for intermittent renewable resources like wind and solar, the availability of
23 generation is a function of underlying meteorological conditions and will

1 vary by time of day and from season to season; for energy storage, the
2 resource's "duration" – the number of hours of stored energy – limits the
3 amount of time it can be operated at full capacity. Energy storage may
4 also be limited by the availability of energy for charging.

5
6 Due to these limitations, the contributions of dispatch-limited resources to
7 reliability are often lower than the resource's rated maximum or
8 "nameplate" capacity (contributions to reliability for conventional resources
9 are also lower than nameplate capacity due to the potential for forced
10 outages). Another consequence of these limitations is that dispatch-limited
11 resources tend to exhibit diminishing returns with scale due to saturation
12 effects. That is, each increment of a specific dispatch-limited resource will
13 tend to have a lower contribution to resource adequacy than the prior
14 increment.


15

16 **Q. How do these concepts apply to the capacity contribution of**
17 **intermittent renewables?**

18 **A.** The output of intermittent renewable resources varies through time due to
19 factors outside of the control of utilities – namely, as a function of
20 underlying weather conditions. Because their output is often lower than
21 their rated capacities during the periods in which energy is most needed,
22 the contribution of intermittent resources to resource adequacy is typically
23 lower than their rated (maximum) capacities. This dynamic is readily

1 apparent for solar PV in a summer-peaking system. The first increment of
 2 solar PV projects added to the system provides moderate capacity value
 3 due to its coincidence with system peak loads, but it also has the effect of
 4 shifting the “net peak demand” – demand less intermittent renewables –
 5 towards the evening, when solar produces less. As a result, subsequent
 6 increments of solar PV will produce lower and lower contributions to
 7 resource adequacy. These dynamics are shown in Figure 1 below, which
 8 is not a model result but illustrates these dynamics conceptually. Similar
 9 dynamics would occur on NorthWestern’s system and could be amplified
 10 by the fact that NorthWestern’s peaks often occur in winter evenings.

11 **Figure 1: Solar Capacity Contribution Dynamics (illustrative)**



12 Similar dynamics as described for solar PV occur for wind generation
 13 capacity contribution as well.

14


15 **Q. How do these concepts apply to energy storage?**

1 **A.** While energy storage resources can be operated flexibly in response to
2 system conditions, they are unable to generate continuously at maximum
3 output for long periods of time. The “duration” – a measure of the amount
4 of time a storage resource can discharge at full capacity before its state of
5 charge is exhausted – may limit the ability of energy storage resources to
6 produce power when needed. For example, a peak load event may
7 require some energy storage resources to discharge continuously for four
8 hours, but if the resources have a duration less than four hours, then the
9 storage resources either run out of energy before the event is over or must
10 operate at partial output over the full period to lower the peak demand
11 across the entire timespan. Once an energy storage resource is depleted,
12 it is unavailable to discharge to help meet system needs until it is able to
13 re-charge. For example, on a particular day, an energy storage resource
14 may discharge during the late afternoon to help meet peak demand, but if
15 an outage occurs at a thermal power plant in the evening when energy
16 demand is still very high, the energy storage resource would be
17 unavailable to respond.

18
19 Like other dispatch-limited resources, the capacity contribution of energy
20 storage resources tends to diminish with increasing levels of penetration.
21 The capacity contribution of storage declines because, as successive
22 tranches of storage reduce peak demand, the next tranche of storage

1 must reduce the peak over a longer period. These dynamics are shown in
2 Figure 2 below, which is not a model result but illustrates these concepts.

3 **Figure 2: Energy Storage Capacity Contribution Dynamics (illustrative)**




4

5 **Q. Are there interactive effects between different types of dispatch-**
6 **limited resources?**

7 **A.** Yes. The contribution of a resource toward resource adequacy depends
8 on the characteristics of the other resources in the portfolio; that is,
9 resources have interactive effects with one another such that a portfolio of
10 resources may provide a capacity contribution that is greater than (or
11 smaller than) the sum of its parts. The combination of solar PV and battery
12 storage is a useful example. These two resources tend to have a positive
13 interactive effect when added to a portfolio. The solar PV generation
14 during the day shifts and compresses the net peak period into a few
15 evening hours, enabling the battery storage to more effectively meet the
16 net peak demand. Thus, the solar PV resource helps to satisfy daytime

1 energy demand while the energy storage resource can help to meet
2 evening energy demand. This dynamic is shown in Figure 3 below, which
3 is not a model result but illustrates this concept. Other resource
4 combinations may produce similar interactive effects.

5 **Figure 3: Capacity Contribution Dynamic of Adding Solar and Energy**
6 **Storage (illustrative)**



7

8 **Q. How do utilities evaluate the contribution of dispatch-limited**
9 **resources toward resource adequacy?**

10 **A.** No single method is used to evaluate the contribution of dispatch-limited
11 resources toward resource adequacy, and historically, many system
12 planners have relied upon relatively simple heuristic methods to estimate
13 capacity contributions such as average output during a 2-6 p.m. time
14 window. However, as more dispatch-limited resources are added to the
15 system, these methods become increasingly inaccurate and fail to capture
16 how the addition of dispatch-limited resources will cause the timing of
17 supply constraints to shift to other times of the day (or year). Further, they
18 do not capture significant interactive effects between different types of

1 technologies. When renewables make up a significant portion of a utility's
2 portfolio, it is important to use an accurate method for calculating the
3 contribution of these resources toward resource adequacy, and the ELCC
4 method has emerged as the industry "best-practice" for estimating the
5 contribution of dispatch-limited resources toward resource adequacy.

6

7 **Q. How is the ELCC of a resource defined?**

8 **A.** The ELCC is a robust measure of a resource's contribution to a utility's
9 reliability standard, defined as the quantity of "perfect" capacity¹ that could
10 be displaced by a resource while providing equivalent system reliability.
11 For example, if a resource has an ELCC of 50 megawatts ("MW") that
12 means that it could displace 50 MW of perfect capacity with no impact on
13 system reliability. The ELCC can also be expressed in percentage terms
14 by dividing by the nameplate capacity; if the resource in this example has
15 a nameplate rating of 100 MW, its ELCC would be 50%.

16

17 Quantifying ELCC values requires the use of a Loss-of-Load Probability
18 ("LOLP") model. An LOLP model simulates the balance of demand and
19 available supply across a broad range of weather conditions to measure
20 the performance of resources during periods of system stress,

¹ A "perfect" capacity resource is a resource that can dispatch on demand at full capacity and is always available.

1 incorporating the effects of any correlations (positive or negative) that
2 might exist between dispatch-limited resource production and load. While
3 the ELCC method considers a resource's performance across all hours
4 and under all possible conditions, the resulting ELCC is a measure of the
5 resource's contribution to system needs during the periods in which it is
6 needed most.

7

8 **Q. Why is the ELCC method preferred over other methods?**

9 **A.** The ELCC method is preferred for three primary reasons:

- 10 1. It captures a wide range of system conditions by simulating electric
11 system operations over hundreds or even thousands of simulation
12 years. This ensures that the estimation of capacity contributions is
13 robust across a wide distribution of potential outcomes, including
14 infrequent "tail" events (e.g. higher load and lower renewable output
15 than expected combined with forced generator outages) that are the
16 primary drivers of reliability challenges.
- 17 2. It naturally accounts for both the saturation effects that occur as a
18 particular resource type is added to the system in increasing quantities
19 and the interactive effects between different types of technologies to
20 provide an accurate measurement of the contribution of dispatch-
21 limited resources to the system.
- 22 3. As a result of the first two characteristics listed above, the ELCC
23 method ties the capacity contribution of a resource directly to its ability

1 to help satisfy the reliability target. This ensures that its deemed
2 capacity contribution corresponds one-for-one to its contribution toward
3 resource adequacy. This approach therefore creates a common metric
4 that ensures an “apples-to-apples” comparison among resources with
5 very different characteristics. A resource with an ELCC of 1 MW has
6 the same contribution toward resource adequacy, regardless of
7 whether that capacity contribution comes from solar PV, wind, energy
8 storage, etc. This makes ELCC a suitable metric for comparing
9 capacity contributions of different resources in capacity procurement
10 solicitations.

11 **E3’s Incremental Effective Load Carrying Capability Study**

12 **Q. How did E3 quantify the ELCC for dispatch-limited resources?**

13 **A.** The ELCC for dispatch-limited resources was quantified using E3’s
14 proprietary Renewable Energy Capacity Planning (“RECAP”) model with
15 input data on NorthWestern’s loads and resources. RECAP is a LOLP
16 model that has been used extensively to test the resource adequacy of
17 electric systems across North America and to measure the contribution of
18 dispatch-limited resources towards resource adequacy. E3 developed
19 RECAP specifically to address the needs of a changing electricity system
20 by incorporating the unique characteristics of dispatch-limited resources
21 into the traditional reliability framework.

22
23 **Q. Please describe, at a high level, how RECAP functions.**

1 **A.** RECAP calculates the loss-of-load expectation (“LOLE”) of a portfolio by
2 simulating the availability of generation to supply load on an hourly basis
3 across a wide range of possible system conditions. The range of
4 conditions simulated captures load and renewable variability (based on an
5 underlying record of weather data from 1970-2018) as well as stochastic
6 outages of generating resources. Correlations among load and renewable
7 generation are maintained within the model to ensure appropriate
8 statistical relationships among load, weather, and renewable generation
9 conditions, based on historical observations. Hourly simulations are
10 completed for hundreds of years of potential conditions to ensure a robust
11 result; this ensures that RECAP captures a wide distribution of potential
12 outcomes, including tail events.

13
14 To determine the LOLE of a portfolio, RECAP compares demand with
15 available generation in each hour of the simulation. A loss-of-load event is
16 recorded each time the supply of resources is inadequate to meet the load
17 requirement. RECAP determines the frequency of loss-of-load events
18 across all simulation years and then calculates the LOLE as the count of
19 loss-of-load events per year.

20
21 **Q. How is the ELCC for dispatch-limited resources determined in**
22 **RECAP?**

- 1 **A.** The steps followed to calculate the ELCC of a particular resource (or
2 combination of resources) in RECAP are as follows:
- 3 1. RECAP is first used to calculate the LOLE for the electric system
4 without the specified resource. If the resulting LOLE does not match
5 the specified reliability target, the system is calibrated to meet the
6 target reliability standard (e.g. 0.1 days/yr.) by adding or removing
7 perfect capacity.²
 - 8 2. The specified dispatch-limited resource is added to the system and the
9 LOLE is recalculated. This will result in a reduction in the system's
10 LOLE, as the amount of available generation has increased and the
11 reliability of the system has improved.³
 - 12 3. Perfect capacity resources are removed from the system until the
13 LOLE is restored to the specified reliability target. The amount of
14 perfect capacity removed from the system represents the ELCC of the
15 specified resource (measured in MW) added in step 2; this metric can
16 be translated to a percentage value by dividing by the installed
17 capacity of the specified resource.

² A reliability target can be based on reliability metrics other than LOLE. This is an area of emerging research for systems with high penetrations of dispatch-limited resources. For this study, E3 utilized a 0.1 days/yr. LOLE reliability metric.

³ E3's method for this study was to use the Expected Unserved Energy ("EUE") equivalent to the 2020 NorthWestern system reaching 0.1 day/yr. LOLE, which was 5 MWh/yr. EUE. This EUE value was used in calculating ELCCs due to its greater granularity compared to the relatively less granular event metric used to define LOLE.

1 **Q. Has RECAP been used to quantify the ELCC of resources in other**
2 **jurisdictions?**

3 **A.** Yes. E3 initially developed RECAP for the CAISO in 2011 to facilitate
4 studies of renewable integration and it has since been adapted for use in
5 many jurisdictions across North America. Multiple utilities have used
6 RECAP for some aspect of resource adequacy planning, including the Los
7 Angeles Department of Water and Power, the Sacramento Municipal
8 Utilities District, Portland General Electric, Xcel Energy, NV Energy, El
9 Paso Electric, Hawaiian Electric, New Brunswick Power, and Nova Scotia
10 Power. The California PUC has also used RECAP for a variety of resource
11 planning proceedings, and E3 worked with the CAISO to use RECAP to
12 examine the ELCC of demand response and energy storage. Finally,
13 RECAP has been used in several of E3's long-term resource planning
14 studies of decarbonized electricity systems, including studies in

1 California,⁴ the Pacific Northwest,⁵ the Upper Midwest,⁶ and the
2 Northeast.⁷

3

4 **Q. Does E3's ELCC study consider or evaluate resource economics?**

5 **A.** No. E3's study evaluates the capacity contribution of resources, which is
6 necessary for evaluating system reliability. E3 did not use RECAP to
7 evaluate resource economics or provide an economic comparison
8 between different resources. The evaluation of the resources proposed in
9 response to the RFP is explained in the Direct Testimony of Scott A.
10 Leigh.

11

12 **Q. How was RECAP configured for modeling NorthWestern's system?**

13 **A.** E3 took the following steps to set up the NorthWestern RECAP model:
14 1. **Load shape development:** E3 developed a neural network model that
15 generates hourly load shapes for the NorthWestern system across

⁴ *Long-Run Resource Adequacy for California Under Deep Decarbonization*, available at: https://www.ethree.com/wp-content/uploads/2019/06/E3_Long_Run_Resource_Adequacy_CA_Deep-Decarbonization_Final.pdf

⁵ *Resource Adequacy in the Pacific Northwest*, available at: https://www.ethree.com/wp-content/uploads/2019/03/E3_Resource_Adequacy_in_the_Pacific-Northwest_March_2019.pdf

⁶ *Xcel Energy Low Carbon Scenario Analysis*, available at: https://www.ethree.com/wp-content/uploads/2020/01/E3_Xcel_MN_IRP_Report_2019-07_FINAL.pdf

⁷ *Net-zero New England: Ensuring Electric Reliability in a Low Carbon Future*, available at: https://www.ethree.com/wp-content/uploads/2020/11/E3-EFI_Report-New-England-Reliability-Under-Deep-Decarbonization_Full-Report_November_2020.pdf


1 multiple years. The model was trained on historical 2010-2018
2 NorthWestern loads, and the trained parameters were used to
3 generate load shapes for 1970-2018 based on historical temperature
4 data. Load shapes used in this analysis were those of the
5 NorthWestern retail electricity supply function customers and captured
6 the dual-peak (i.e. both summer and winter) nature of the system.

7 **2. Resource shape development:** E3 used historical wind and solar
8 data provided by NorthWestern for existing resource output. RECAP's
9 algorithm calculates hourly renewable output shapes across the full
10 range of simulated years using A) historical renewable output in similar
11 seasons (+/- 15 calendar days to the simulated day) to capture inter-
12 annual variations in renewable energy output, B) historical correlations
13 with load to capture any positive or negative correlations between load
14 and renewable energy output, and C) correlations with the previous
15 day's renewable generation to capture the frequency of multi-day
16 sequences of extreme heat, extreme cold, or extremely low renewable
17 energy output. This algorithm is applied stochastically for each Monte
18 Carlo simulation.


19 **3. Add the existing resources in NorthWestern's supply portfolio:**
20 NorthWestern's existing resources were added to RECAP, and their
21 operations were simulated in the model runs used to develop the
22 incremental ELCCs.

- 1 4. **Adding perfect capacity to NorthWestern’s system to meet a**
2 **LOLE of 1 day in 10 years:** Per standard practice, the system was
3 “tuned” to 0.1 LOLE by adding perfect capacity resources, prior to
4 calculating the incremental ELCCs.
- 5 5. **Adding renewable generation shapes for new resources:** For new
6 wind incremental ELCCs, historical NorthWestern wind output shapes
7 (over 2014-2018) were used as the basis for modeling wind output in
8 RECAP. For new solar incremental ELCCs, simulated output shapes
9 (over 2014-2018) were used to better represent the best-in-class
10 tracking PV technologies expected from solicitation proposals.
11 Simulated solar shapes were derived by using the National Renewable
12 Energy Laboratory’s (“NREL”) National Solar Radiation Database and
13 NREL’s System Advisor Model. Figure 5 and Figure 6 show the month-
14 hour average wind and solar profiles modeled in RECAP.

1 **Figure 4: Wind Output Data used in E3's ELCC Calculations (Month/Hour**
2 **averages)**



3
4 **Figure 5: Solar Output Data used in E3's ELCC Calculations (Month/Hour**
5 **averages)**



6
7 **Q. How were hybrid resource ELCCs modeled?**

1 **A.** Both hybrid wind and hybrid solar resources were modeled in various
2 project configurations. E3 modeled some configurations of hybrid
3 resources that could charge from the grid, enabling the storage to charge
4 sufficiently using grid electricity to provide their full reliability benefit. E3
5 also modeled some configurations of hybrid resources that could only
6 charge from their co-located solar or wind resource, which limits their
7 ability to sufficiently charge the storage during loss-of-load events
8 modeled in RECAP. This limitation means that variable energy resource
9 (“VER”)-only charging hybrids had lower ELCCs than hybrid resources
10 that could charge from the grid. However, some developers may choose
11 to limit grid charging to enable capturing of the full investment tax credit for
12 both the solar and storage components of their project.

13
14 Hybrid resources were modeled in various ratios of VER capacity to
15 storage capacity. All hybrid resources were modeled with 4-hour battery
16 durations, and all hybrid resource ELCCs were limited by their joint
17 interconnection capacity limit. Solar hybrid resources were modeled in
18 both AC-coupled and DC-coupled conditions. As shown in the chart
19 below, AC-coupled systems feature two AC-to-DC inverters, one for the
20 solar array and another for the battery system, while DC-coupled systems
21 site both the solar array and the battery behind a single inverter. E3


1 modeled a 1.3 inverter loading ratio for AC-coupled hybrids and a 1.7
2 inverter loading ratio for DC-coupled hybrids.⁸

3

4 **Figure 6: AC-Coupled vs. DC-Coupled Hybrid System Configurations**

5

(source: Fluence Energy⁹)



6

7

ELCC Calculation Results

8

Q. What were the results of E3’s incremental ELCC calculations?

⁸ Inverter loading ratio (“ILR”) describes the ratio of DC capacity behind the AC-to-DC inverter to the final AC output from that inverter. A 1.3 ILR means that there are 130 MW_DC of solar PV behind a 100-MW inverter. DC-coupled hybrid systems often feature higher ILRs because the energy that would have been “clipped” due to the inverter capacity limits can instead be stored in the battery behind the same inverter. A 1.7 ILR means that there are 170 MW_DC of solar PV behind a 100-MW inverter, which allows additional energy that can be used to charge the storage device.

⁹ <https://blog.fluenceenergy.com/energy-storage-ac-dc-coupled-solar>

1 **A.** E3 calculated incremental ELCCs for the resource types, resource
 2 penetrations, and resource configurations shown in the tables below.
 3 Table 1 and Table 2 below contain the final set of incremental ELCC MW
 4 and ELCC percentage values across the resources studied that E3
 5 provided to NorthWestern in July 2020. These final results are presented in
 6 Exhibit AO-2.

7 **Table 1: E3’s Effective Capacity and Incremental ELCC of Standalone**
 8 **Resources Results from July 2020 Study (ELCC MW and Incremental ELCC**
 9 **vs. Nameplate MW additions)¹⁰**

Effective Capacity Provided by Different Resources, 2020									
Incremental Nameplate Capacity (MW)	Charging From	25 MW	50 MW	100MW	200MW	300MW	400MW	500MW	
Standalone Battery	4hr	Grid	25	50	100	181	217	243	263
Pumped Storage	10hr	Grid			100	200	290	323	343
Solar PV	Simulated			2	4	6	7		
Wind	Historical			3	5	10	14		

Incremental ELCC Provided by Different Resources, 2020									
Incremental Nameplate Capacity (MW)	Charging From	25 MW	50 MW	100MW	200MW	300MW	400MW	500MW	
Standalone Battery	4hr	Grid	100%	100%	100%	91%	72%	61%	53%
Pumped Storage	10hr	Grid			100%	100%	97%	81%	69%
Solar PV	Simulated			5%	4%	3%	2%		
Wind	Historical			6%	5%	5%	5%		

10 These results are shown as the ELCC MW for the capacity being added, e.g. 200 MW of 4-hr standalone battery storage provides 181 MW of ELCC (i.e. the equivalent perfect capacity)..

1 **Table 2: E3’s Effective Capacity and Incremental ELCC of Hybrid Resources**
2 **Results from July and November 2020 Studies (ELCC MW and Incremental**
3 **ELCC vs. Nameplate MW additions)¹¹**

Capacity Value of a 100MW Incremental Paired Hybrid, 2020	4-Hr Storage Hybrid Configuration	Charging From:	Effective Capacity (ELCC MW)	Incremental ELCC (%)
100 MW Solar + 4-Hr Storage	25 MW (AC-coupled)	Grid	29	29%
	50 MW (AC-coupled)	Grid	54	54%
	100 MW (DC-coupled) ^x	Grid	100	100%
	200 MW (AC-coupled)*	Grid	196	196%
	25 MW (AC-coupled)	Solar Only	24	24%
	50 MW (AC-coupled)	Solar Only	43	43%
	100 MW (DC-coupled) ^x	Solar Only	66	66%
	125 MW (AC-coupled)*	Solar Only	58	58%
	200 MW (AC-coupled)*	Solar Only	65	65%
100 MW Wind + 4-Hr Storage	25 MW	Grid	30	30%
	50 MW	Grid	54	54%
	100 MW	Grid	100	100%
	25 MW	Wind Only	25	25%
	50 MW	Wind Only	46	46%
	100 MW	Wind Only	56	56%
	125 MW*	Wind Only	60	60%

Values in blue represent hybrids with ability to charge from the grid

^xDC-coupled Solar resources assumed to have an inverter loading ratio of 1.7

*Interconnection limit is assumed to be matched with the capacity of the largest resource

Bold and Italicized Values denotes additional hybrid configurations from Nov 2020 Study

4

¹¹ Hybrid resources were modeled at various storage sizes relative to the 100 MW_AC addition of co-located wind or solar. Hybrid resources were subject to an interconnection limit based on the larger of the resources. For instance, the “200% of solar PV” project assumes 100 MW_AC solar PV and 200 MW of energy storage, subject to a maximum 200 MW output based on the assumed interconnection limit.

1 Observations from ELCC Calculation Results

2 **Q. What dynamics were observed in the incremental ELCC modeling**
3 **results?**

4 **A.** E3 observed the following dynamics for the incremental ELCCs:

- 5 • **Energy storage:** NorthWestern has no utility-scale energy storage
6 (except for a small amount of water storage within the hydro system)
7 on its system currently and the first 100 MW of 4-hr and 10-hr storage
8 additions provide essentially 100% of their capacity in ELCC MW. By
9 200 MW of storage additions, incremental ELCCs begin to decline, for
10 instance adding 200 MW of 4-hour storage provides only 181 MW of
11 ELCC. This dynamic continues as the MW of storage penetrations
12 increases, but is mitigated to an extent if storage of longer duration is
13 also added.
- 14 • **Solar PV:** Driven by the fact that solar output is quite low during
15 NorthWestern's winter peaks, solar provides very low incremental
16 ELCC MW for new additions. Saturation effects are also present in
17 these results, with 100 MW providing 4 MW ELCC (4%) and 300 MW
18 of additions providing 7 MW ELCC (2%).
- 19 • **Wind:** Given the significant penetration of wind already in
20 NorthWestern's supply portfolio, incremental wind additions tend to
21 provide low ELCC MW (5-6%) to NorthWestern's system. Historical
22 shapes were used for calculating incremental ELCCs since they

1 captured actual performance of wind on NorthWestern’s system
2 (including cold temperature cut outs, maintenance outages, etc.).

- 3 • **Hybrid resources:** Hybrid resources were all tested at 100 MW-AC of
4 either wind or solar additions, with varying levels of 4-hour battery
5 storage and either grid or VER-only charging configurations. The
6 configurations that allowed grid charging showed ELCCs similar to the
7 sum of the stand-alone VER and the stand-alone storage device.
8 However, when added as a hybrid resource, there is also a “diversity
9 benefit” that the resources may provide. Solar and storage hybrid
10 additions provide slightly more than the sum of the stand-alone
11 systems for this reason. Hybrid resources that limit charging to the
12 VER resource and do not allow grid charging tend to show lower ELCC
13 values than the equivalent grid-charging hybrid. This is because the
14 storage may not be able to fully charge with only VER energy before a
15 loss-of-load event. DC-coupled solar hybrid configurations are less
16 impacted by this dynamic than AC-coupled solar hybrid configurations,
17 though the impact still exists. This is because DC-coupled solar
18 hybrids were modeled with a higher inverter loading ratio of 1.7 (vs. 1.3
19 for AC-coupled solar hybrids), which provides more solar DC capacity
20 behind the shared inverter that can be used for charging the storage
21 device.

1 **Q. What are the differences between the July ELCC results, the**
 2 **November ELCC results?**

3 **A.** E3 first performed an incremental ELCC study for NorthWestern that was
 4 delivered in July 2020. NorthWestern subsequently asked E3 to update
 5 the study in November 2020 with additional hybrid configuration types.
 6 The ELCC study results dated November 2020 contain the same ELCCs
 7 as the July 2020 study, except for the VER-only charging hybrid resources
 8 and additional hybrid configurations added to the study. The updated
 9 November 2020 vintage study is provided as Exhibit AO-3.

10

11 **Q. In addition to the generic ELCC resources presented, were**
 12 **calculations done on specific proposals received by NorthWestern?**

13 **A.** Yes, In January 2021, E3 also calculated specific ELCCs for a limited set
 14 of proposals, per NorthWestern’s request. The results of this analysis are
 15 captured in Table 3 and are described in more detail in E3’s memo,
 16 attached as Exhibit AO-4.

17 **Table 3: E3’s Effective Capacity of Hybrid Proposals Calculated in January**

18

2021


Project ID	Type	Configuration	Coupling	ILR	Project Export Capability (MW)	VER-Only Charging	Grid-Charging
012-1.4	Wind + ESS	60 MW + 20 MW/5-hr	AC	-	60	36	36
014-1.3	Solar + ESS	80 MW + 30 MW/5-hr	DC	1.75	80	32	33
014-2.3	Solar + ESS	300 MW + 150 MW/5-hr	DC	1.75	300	151	154
020-3.4	Wind + ESS	100 MW + 100 MW/5-hr	AC	-	105	102	105
053-1.1	Solar + ESS	100 MW + 30 MW/5-hr	AC	1.2	130	33	33
053-1.2	Solar + ESS	200 MW + 200 MW/5-hr	AC	1.2	200	197	200

19

1 **Q. How were specific proposals received by NorthWestern modeled in**
2 **RECAP?**


3 **A.** Consistent with the July and November 2020 ELCC studies, E3 calculated
4 specific ELCCs using RECAP. To represent specific bids, E3 used bid-
5 specific energy output profiles provided by NorthWestern. Figure 8 and
6 Figure 9 show the month-hour average wind and solar profiles used in the
7 January 2021 analysis.

8 **Figure 7: Bid-Specific Wind Output Data used in January 2021 ELCC**
9 **Calculations (Month/Hour averages)**



10

1 **Figure 8: Bid-Specific Solar Output Data used in January 2021 ELCC**
2 **Calculations (Month/Hour averages)**



- 3
- 4 **Q. Does this conclude your direct testimony?**
- 5 **A. Yes, it does.**

VERIFICATION

This Direct Testimony of Arne Olson is true and accurate to the best of my knowledge, information, and belief.


Arne Olson